



NEMSU HOLDINGS (PVT) LTD


QUALITY ASSURANCE DEPARTMENT

PRODUCT SPECIFICATION

Revision no	00
Amendment no	00
Date of Issue	8/1/2021
Page	2 of 10

NAME OF PRODUCT : Electrical Conduits SLS Pipes (SLS 993)

BRAND: NEMSU



Nominal Diameter (mm)	Mean Outside Diameter (mm)		Wall Thickness(mm)		Length(mm)
	Min	Max	Min	Max	
16	15.7	16.0	0.7	1.0	4000
20	19.7	20.0	0.9	1.2	4000
25	24.6	25.0	1.0	1.3	4000
32	31.6	32.0	1.2	1.5	4000
40	39.6	40.0	1.5	1.9	4000
50	49.5	50.0	1.9	2.2	4000

DATE- 21/07/2023

Approved By:

Q.A. Manager

S. Wickramanathane